

Date d'édition : 15.11.2024

Ref : 8-2214010-100-12-0

BS 0.1 Branchement de maison



BS 0.1 Transformer and house service connection The Mains voltage for the training unit is supplied by an isolating transformer 230/230 V/AC with a power output of 200 VA. A 1 A automatic circuit-breaker protects the installation from over-load and short-circuit. The module includes an insulation monitoring device to interrupt the supply to the training equipment as soon as one of the live conductors is connected to the ground of the training equipment or a module presents a short-circuit to frame. After the removal of the fault, the module is ready for operation after it is turned on again.